

1.1.1 TP/F4



Test Pit TP/F4, looking south, showing wall foundations [31]

TP/F4	
Location	Farringdon Eastern Ticket Hall, 8-10 Hayne Street basement.
Dimensions	2m (N to S) x 2.7m (E to W) at top x 1.4m deep (max)
London Survey grid coordinates	?
Ordinance Survey grid coordinates	?
Modern Ground Level (adjacent to pit)	10m OD (110m ATD)
Modern subsurface deposits	19th/20th-century made ground/backfill [26]: 0.45m bgl – Dark brown mixed clayey silt and gravel, with occasional brick rubble. Cut by Wall and foundations [31] and construction cut [32], concrete pad 0.8m bgl.
Level of base of archaeological deposits observed and/or base of pit	N/A

Natural geology observed (truncated/not truncated ?)	London Clay [27]: soft brownish grey clay at
Extent of modern truncation	Whole area of pit
Archaeological and built heritage remains	Date
None	N/A
Pit interpretation and summary	
<p>Foundations of wall [33] consisted of a concrete pad (extending 600mm from the face of the wall and >0.6m deep/thick). The concrete pad continued north, south and down beyond the limit of the excavation.</p> <p>No archaeological remains were present in the pit.</p>	

1.1.2 TP/G4



Test Pit TP/G4, looking west, showing wall foundations [33]

TP/G4	
Location	Farringdon Eastern Ticket Hall, 8-10 Hayne Street basement.
Dimensions	1.5m (N to S) x 2.5m (E to W) at top x 1.2m deep (max)

London Survey grid coordinates	?
Ordinance Survey grid coordinates	?
Modern Ground Level (adjacent to pit)	14m OD (114m ATD)
Modern subsurface deposits	<p>19th/20th-century made ground/backfill [28]:</p> <p>0.4m bgl – Yellow grey sandy clay with occasional brick rubble, flecks of mortar and sub-angular stones.</p> <p>Cut by wall and foundations [33] and construction cut [34]: corbelling 0.14m bgl, concrete pad 0.5m bgl.</p>
Level of base of archaeological deposits observed and/or base of pit	N/A
Natural geology observed (truncated/not truncated ?)	Not reached
Extent of modern truncation	Whole area of pit
Archaeological and built heritage remains	Date
None	N/A
Pit interpretation and summary	
<p>Foundations of wall [33] consisted of brick corbelling (stepped/pyramid)(4 steps, c.360mm high and extending c.200mm from the face of the wall) sitting on a concrete pad (extending 440mm from the face of the wall and >0.7m deep/thick). The concrete pad continued east, west and down beyond the limit of the excavation.</p> <p>No archaeological remains were present in the pit.</p>	